

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. PHED/256/2028

Dated: 20/07/2028

It is certified that an inspection team headed by Mr. Sanjay Singh (Asst. Engineer)

(Name of Officers with designation) from Public Health Department PHED

inspected the Royal Public School - Majari Kahu Koushambi

(Name & Address of the school) on 20/07/2028 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. Chemical Test 224/2028-28 dated 18.07.2028

of U.P. Jal Kal. Nigam (PHED Lab) certified that

the Royal Public School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till One year

Signature with Seal: Sanjay Singh

Name

Designation

Name & Address of the Office / Department: PHED

To Royal Public School
Majari Kahu Koushambi
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Sanjay Singh
Public Health Officer
Koushambi



Analysis Report

District Level Water Analysis Laboratory, U.P. Jal Nigam
(Rural), Kaushambi



Rept. No. Chemical Test 284/2025-2026 Date 18-07-2025 Page No. 1 Page 1/1

Customer Details

Office Name & Address	Royal Public School		
Ref Letter No. & Date	Date 18-07-2025		
Basic Details of sample			
District	Kaushambi	Block	kada
Gram Panchayat	Kada	Village	Mogari
Habitation		Location	Mogari Kada Kaushambi
Water Source	R.O. Water	Sample No.	284
Quantity of Sample	100 ml.	Date of Sample Collection	18-07-2025
Receiving Date	18-07-2025	Sample Collector	By the customer: Ram Shubhag Tripathi
Sample Depositor	By the customer : Aman Singh		
Analysis Start Date	18-07-2025	Analysis Completion Date	18-07-2025

Environment Condition

Temperature	25±3°C	Humidity	50±15%
-------------	--------	----------	--------

Technical Data of Analysis

S No.	Parameter	Units	Observed Value	Specified Values as per		Ref. Method of Analysis
				Acceptable limit	Permissible limit	
1	2	3	4	5	6	7
1	Turbidity	(NTU)	3.6	1.00	5.00	IS 3025 (Part 10) : 2023
2	pH Value		7.38	6.5-8.5	6-5-8.6	IS 3025 (Part 11) : 2012 (RA : 2022)
3	TDS	(mg/L)	430	500.00	2000	IS 3025 (Part 16) : 2023
4	Fluoride	(mg/L)	0.225	1.00	1.5	IS 3025 (Part 60) : 2008 (Electro. Chem. Prob Meth)
5	Chloride	(mg/L)	39.9876	250.00	1000	IS 3025 (Part 32) : 2014 (RA: 2019)
6	Iron	(mg/L)	0.38	0.30	1	APHA 23 rd Edition – 3500- Fe Method B (Phenanthroline)
7	Sulphate	(mg/L)	11.95	200.00	400	IS 3025 (Part – 24) : 2009 (RA:2022)
8	Nirate	(mg/L)	14.48	45.00	45	APHA 24rd Edition 2023, Meth, 4500 NO ₃ -B
9	T. Alkalinity	(mg/L)	300	200.00	600	IS 3025 (Part 23) : 2023
10	T. Hardness	(mg/L)	340	200.00	600	IS 3025 (Part 21) : 2009 (RA: 2023)
11	Calcium	(mg/L)	32.064	75.00	200	IS 3025 (Part 40) : 2019
12	Magnesium	(mg/L)	63.18	30.00	100	IS 3025 (Part 46) : 2019
13	Taste	Qualitative	Agreeable	-	-	IS 3025 (Part 08) : 2023
14	Odour	Qualitative	Agreeable	-	-	IS 3025 (Part 05) : 2018
15	Colour	Hazen	5	5	15	IS 3025 (Part 04) : 2021

- Note: 1. This certificate refers only to the particulars sample (s) submitted for testing.
2. This certificate shall not be reproduced, except in full in full, unless written permission for the publication of an approved abstract has been obtained from Head Of laboratory.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 7 days (in case of non perishable items) from the date of issue of test reports unless otherwise specified.

Lab Technician
Prepared By

Authorised Signatory
(Technical Manager)

** End of Test Report **

Contact details – Email – upjnlab@gmail.com Mob- 8382820011